

**MIDCONTINENT**

TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

KURT SLENTZ
PINE GROVE
23734 LIMESTONE LANE
RAPID CITY, SD 57702

Sample Site: Well #1
Sampled: 01/10/21 at 04:20 PM
by Kurt Slentz
EPA Number: 0948
Pine Grove
Sample Matrix: Water

Lab ID#: 20210111903
Received: 01/11/21 at 09:20 AM
by Dean Aurand
Account: 9441
Pine Grove Community Water Assoc.

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
-----------	--------	-------	----	-----	-----	--------	--------------

Physical Properties

Total Dissolved Solids	153	mg/L	100ml	14.7	50.0	SM 2540 C	JNM 01/12/21
------------------------	-----	------	-------	------	------	-----------	--------------

Metals - Dissolved

Calcium (Ca)	46.1	mg/L	1	0.099	1.00	SM 3111 B	TMS 01/12/21
Magnesium (Mg)	15.3	mg/L	1	0.099	0.500	SM 3111 B	TMS 01/12/21
Potassium (K)	2.47	mg/L	1	0.187	0.500	SM 3111 B	TMS 01/12/21
Sodium (Na)	11.0	mg/L	1	0.137	0.500	SM 3111 B	TMS 01/12/21

Approved By:

Steve Distau

Approved On: 1/18/2021 1:51:36 PM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

KURT SLENTZ
PINE GROVE
23734 LIMESTONE LANE
RAPID CITY, SD 57702

Sample Site: Briggs
Sampled: 01/10/21 at 04:10 PM
by Kurt Slentz
EPA Number: 0948
Pine Grove
Sample Matrix: Water

Lab ID#: 20210111904
Received: 01/11/21 at 09:20 AM
by Dean Aurand
Account: 9441
Pine Grove Community Water Assoc.

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Volatile							
Bromodichloromethane	< 0.500	µg/L	1	0.058	0.500	EPA 524.2	RAM 01/13/21
Bromoform	< 0.500	µg/L	1	0.074	0.500	EPA 524.2	RAM 01/13/21
Chlorodibromomethane	< 0.500	µg/L	1	0.050	0.500	EPA 524.2	RAM 01/13/21
Chloroform	< 0.500	µg/L	1	0.058	0.500	EPA 524.2	RAM 01/13/21
Calculated Totals							
Total Trihalomethanes	< 2.00	µg/L	1			EPA 524.2	SCR 01/18/21

Approved By:

Steve Distau

Approved On: 1/18/2021 1:51:36 PM